

IT-30004

Built-in Fire Shut Off Fuse



PRODUCT FEATURES

- Adjustable thermostat between 60°F and 120°F
- Humidistat setting between 30% to 90%
- Rated for up to 4 Amps
- Only for use with QuietCool power ventilators

WIRING INSTRUCTIONS

DANGER: Electrical connections on all wiring must be done by a qualified electrician in accordance with all local codes and standards, including fire-rated construction. Failure to complete installation properly can result in fire or even death.

WARNING: Turn off the electrical current to the unit before attempting any service work.

FOLLOW ALL WIRING DIAGRAMS AND ALL INSTRUCTIONS CAREFULLY. CONNECT TO 115-120V CIRCUIT ONLY.

- 1. Turn off power to unit at breaker box.
- 2. If you are replacing an existing thermostat or humidistat.
- 3. Disconnect wiring from the existing thermostat or humidistat.
- 4. Remove old thermostat or humidistat and box from fan at conduit connection in box.
- 5. Connect one black wie from the humidistat to the black wie of the incoming power supply.
- 6. Connect the other black wire from the humidistat to the black motor wire.
- 7. Connect the white wire from the power supply to the white motor wire.
- Attach the ground wire from the incoming power supply and the ground wire from the motor to the ground screw on the control box.

CAUTION: Incorrect wiring can cause motor failure and possible fire.

- R eplace cover on the thermostat/humidistat. Check all connections to be sure there are no exposed conductors.
- 10. Set the temperature/humidistat control at your desired temperature and humidity.
- 11. Restore power to the circuit.

